



Certificado AENOR de Producto



042/000967

AENOR certifica que la organización

MIGUELEZ, S.L.

con domicilio social en AV PARROCO PABLO DIEZ, 157
24010 TROBAJO DEL CAMINO (León - España)

suministra **Cable con resistencia intrínseca al fuego, destinado a circuitos de seguridad, con aislamiento de silicona y cubierta de poliolefina, conductor flexible (0,6/1kV).**

conforme con UNE 211025:2020

Designación SZ1-K 0,6/1 kV PH 120 (AS+)
Marca Comercial MIGUELEZ AFIREFENIX
Limitación De 1x1,5 mm² a 1x240 mm²; De 2x1,5 mm² a 2x35 mm²;
De 3x1,5 mm² a 3x70 mm²; De 4x1,5 mm² a 4x120 mm²;
De 5x1,5 mm² a 5x95 mm²

Resistencia al Fuego PH 120


Centro de producción AV PARROCO PABLO DIEZ, 157
24010 TROBAJO DEL CAMINO (León - España)

Esquema de certificación Para conceder este Certificado, AENOR ha ensayado el producto y ha comprobado el sistema de la calidad aplicado para su elaboración. AENOR realiza estas actividades periódicamente mientras el Certificado no haya sido anulado, según se establece en el Reglamento Particular RP 042.01.

Este certificado anula al 042/000967, de fecha 2018-07-03

Primera emisión 2009-03-17
Modificación 2023-03-24
Expiración 2028-03-24

Rafael GARCÍA MEIRO
CEO





AENOR Product Certificate



042/000967

AENOR certifies that the organization

MIGUELEZ, S.L.

registered office AV PARROCO PABLO DIEZ, 157
24010 TROBAJO DEL CAMINO (León - Spain)

supplies **Cable with intrinsic resistance to fire, intended for use in emergency circuits, rubber silicone insulated and polyolefin sheathed, flexible conductor (0,6/1kV).**

in compliance with UNE 211025:2020

Designation SZ1-K 0,6/1 kV PH 120 (AS+)
Trade Mark MIGUELEZ AFIREFENIX
Restriction From 1x1,5 mm² to 1x240 mm²; From 2x1,5 mm² to 2x35 mm²;
From 3x1,5 mm² to 3x70 mm²; From 4x1,5 mm² to 4x120 mm²;
From 5x1,5 mm² to 5x95 mm²

Resistance to fire PH 120

Production site AV PARROCO PABLO DIEZ, 157
24010 TROBAJO DEL CAMINO (León - Spain)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 042.01.

This certificate supersedes 042/000967, dated 2018-07-03

First issued on 2009-03-17
Modified on 2023-03-24
Validity 2028-03-24

Rafael GARCÍA MEIRO
CEO

